

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Satisfactory

The school is currently undergoing renovation with a New Building .

There were no students located at the facility during the time of inspection.

Email Address(es): arevilla@dadeschools.net

Violations Comments

Violation #5. Maintenance & Repair

Replace inoperable light bulbs in rooms 222, 227, and the cafeteria.

Repair loose wire box in back left of room 205.

Repair loose wire box in front of room 201.

Replace missing ceiling tile in library.

Replace water stained ceiling tile in room 104.

Provide missing light fixture cover in room 232D.

Provide missing wall outlet cover for room 103.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Inspection Conducted By: Abigail DeFabio (027431)
Inspector Contact Number: Work: (305) 623-3500 ex.
Print Client Name: Glades Middle School
Date: 7/7/2020

Inspector Signature:

A handwritten signature in black ink, appearing to be "Abigail DeFabio".

Client Signature:

emailed to client